



**CITY OF
MARION FIRE DEPARTMENT
FIRE CHIEF TIM BARNETT
204 NORTH COURT ST
MARION, IL 62959-2421
Phone: 618-997-5730 · fax: 618-997-5762
www.marionfire.us**

FIRE DEPARTMENT CODE REQUIREMENT

The City of Marion Fire Department has adopted the 2018 edition of the International Fire Code and the 2015 edition of the NFPA 101 Life Safety Code. In addition to the code. The following items must be adhered to for new construction and remodels.

- Smoke Detection – Smoke detection must be 110 volt hardwired installed in all bathrooms. If no alarm system is required, then an additional smoke detector must be installed outside the bathroom. All detectors must be interconnected.
- Emergency Lighting is required in all the bathrooms greater than 100ft³.
- If sprinkled, the FD connection must be 30° down with 5 Storz”.
- If hydrants are to be installed, they must be Kennedy with 5 Storz” & 2-2 ½ with no adapters. Hydrants should be within 100’ of the FD connection.
- If a Hood System is installed. The Fire Dept. must be called to inspect the exhaust duct prior to being wrapped. If a suppression system is installed, the Fire Dept. must be called to witness an balloon and alarm test. All hood systems must be tied into an alarm system that notifies the Marion Dispatch at (618) 997-7500.
- If a sprinkler system is required per code, the Fire Dept. must be called to witness a Flow Alarm test & notification.
- If an alarm system is required, the Fire Dept. must be called to witness the Alarm test & notification to the Police Dept. @ 997-7500.
- Address numbers shall be numerals or alphabet letters. Numbers shall be a minimum of 4 inches high and be visible from the street.
- Must call for a final inspection prior to receiving a commercial occupancy permit.
- If an alarm or sprinkler system is installed, a Knox box must be installed and located on the right side of the front door at a height of four to eight feet.
- If an inverter is used to supply power for emergency lighting, it must be accessible with a 4 foot ladder for testing.

John Barwick
Fire Commissioner

Mike Absher
Mayor

Tim Barnett
Fire Chief